DGL 11 Boden Road, Seven Hills NSW

Environment Protection Licence #141 - 19 June 2025

EPA Licence Conditions, Special Frequency 1 Reporting

(weekly + prior to any discharge from Point 1 - 100 Percentile Concentration Limit)

http://www.epa.nsw.gov.au/prpoeo/index.htm

Date of Sample	Time of Sample	Location Sample Taken	Sample Taken By	Tested By	pH (6.5 - 9)	Turbidity (<50NTU)	Oil & Grease (none visible)	Conductivity (<300µS/cm)	Dissolved Oxygen (<60%)	Comment
2/07/2025	8.30 am	Pool-3	Bill Manning	Ruwan Abeyrathne	7.26	24.05	Not visible	169	55.7	Discharged.
10/07/2025	9.00 am	Pool-3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Dry (checked by Ruwan Abeyrathne)
17/07/2025	9.00 am	Pool-3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No rain - insufficient water for sampling/testing. No discharges. (checked by Ruwan Abeyrathne)
24/07/2025	9.00 am	Pool-3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No rain - insufficient water for sampling/testing. No discharges. (checked by Ruwan Abeyrathne)
31/07/2025	8.30 am	Pool-3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Insufficient water for sampling/testing. No discharges. (checked by Ruwan Abeyrathne)
4/08/2025	9.30 am	Pool-3	Bill Manning	Ruwan Abeyrathne	6.94	12.64	Not visible	190	46.10	TBD